



## FIRE RESISTANT TIMBER FIRE DOORS

**Certificate number: IFCC 1503**

Certificate only valid if verified on website – [www.ifccertification.com](http://www.ifccertification.com)

Issued by IFC Certification Ltd part of the Kiwa UK Group

This is to certify that

### **Solidcor Ltd**

**Unit 5, Sheepbridge Lane  
Chesterfield  
S41 9RX  
Tel: 01246 264245**

Who fabricate the following timber fire doors and or doorsets:

### **Solidcor Fire & Smoke Door System R30 & R60 Doorsets T30 Laminated Doorsets**

have satisfied the requirements of the SDP 01 Fire resistant Timber Door scheme v3.8. This includes the testing of products to **BS EN1634-1:2014+A1:2018** and **BS EN1634-3:2004**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 60 minutes integrity and up to 30 minutes insulation** are detailed on page 2 of this certificate.

Initial Certification: 25 June 2019  
Reissued: 15 May 2024  
Revised: 17 February 2025  
Valid to: 24 June 2029  
Issue number: 7

David Mowatt  
Head of IFC Certification /  
Kiwa Group Limited


*This certificate consists of 2 pages.  
Publication of this certificate is permitted.*



The production of fire-resistant timber doorsets are manufactured in accordance with assessment/ test reports referenced within the following table:

Doorset Description	Fire Rating	Assessment/Test Report
R30 Doorsets	E30	PAR/19437/01
R30 Doorsets with Fanlights	E30	CFR200626_1
R30 Doorsets with Sidelights and Fanlights	E30	WF520980/R
R30 Brampton	EI30	EUI-20-B-000196B
R30/R60 Doorsets	Smoke	W18322-4 W18322-5
R30 with Fanlight	Smoke	W20174-1
R60 Doorsets	E60	PAR/22410/01
T30 Laminated Timber Doorsets	E30	PAR/25132/01

Signed on behalf of Kiwa UK



David Mowatt  
Head of IFC Certification /  
Kiwa Group Limited

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

**It is the certificate holder's responsibility to ensure that the latest version/ revision of the above assessment reports are maintained as part of the audited FPC system.**

**Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.**

# CERTIFICATE